

City of Las Vegas Code and Interpretation

AMEND: 64

DATE: 12-31-09

CODE:	2006 IBC <input type="checkbox"/>	2005 NEC <input checked="" type="checkbox"/>	Local Amendments <input checked="" type="checkbox"/>
	2006 IRC <input type="checkbox"/>	2006 UMC <input type="checkbox"/>	POOL CODE <input type="checkbox"/>
	2006 IECC <input type="checkbox"/>	2006 UPC <input type="checkbox"/>	MISC. <input type="checkbox"/>

CODE SECTION: NEC 220.14, 220.16

TOPIC: Single Family Dwelling plan revision for seven or less electrical receptacles added to the general lighting circuit

PURPOSE/REASON: To update previous inter-office memorandum to Code and Policy Interpretation

INTERPRETATION: Plan revisions are **NOT** required for seven or less additional electrical receptacles added to the general lighting circuit (this includes the general use receptacles as defined in Art 220.14(J)). If more than seven receptacles are added this will required revised plans due to the additional circuit that will be required in the electrical panel.

Plan revisions will be required for any dedicated 120 or 240 volt outlets or circuits that are added. These additions must be accounted for on the load calculations and floor plan.

Additional plan revisions are **NOT** required for adding low voltage outlets (cable TV, computer, telephone, etc.)

Approved: Chris Knight, Building Official